



Presented By
Woonsocket Water Division



ANNUAL
WATER
QUALITY
REPORT

WATER TESTING PERFORMED IN 2015


Meeting the Challenge

Once again we are proud to present our annual drinking water report, covering all drinking water testing performed between January 1 and December 31, 2015. Over the years, we have dedicated ourselves to producing drinking water that meets all state and federal standards. We continually strive to adopt new methods for delivering the best quality drinking water to your homes and businesses. As new challenges to drinking water safety emerge, we remain vigilant in meeting the goals of source water protection, water conservation, and community education while continuing to serve the needs of all of our water users.

Please remember that we are always available to assist you, should you ever have any questions or concerns about your water. our water.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/hotline>.



Information on the Internet

The U.S. EPA (www.epa.gov/Your-Drinking-Water) and the Centers for Disease Control and Prevention (www.cdc.gov) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation and public health. Also, the Rhode Island Department of Health has a Web site (www.health.ri.gov/water/about/yourwater) that provides complete and current information on water issues in Rhode Island, including valuable information about our watershed.

Substances That Could Be in Water

To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, in some cases, radioactive material, and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and may also come from gas stations, urban stormwater runoff, and septic systems;

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Tap vs. Bottled

Thanks in part to aggressive marketing, the bottled water industry has successfully convinced us all that water purchased in bottles is a healthier alternative to tap water. However, according to a four-year study conducted by the Natural Resources Defense Council, bottled water is not necessarily cleaner or safer than most tap water. In fact, about 25 percent of bottled water is actually just bottled tap water (40 percent according to government estimates).

The Food and Drug Administration is responsible for regulating bottled water, but these rules allow for less rigorous testing and purity standards than those required by the U.S. EPA for community tap water. For instance, the high mineral content of some bottled waters makes them unsuitable for babies and young children. Further, the FDA completely exempts bottled water that's packaged and sold within the same state, which accounts for about 70 percent of all bottled water sold in the United States.

People spend 10,000 times more per gallon for bottled water than they typically do for tap water. If you get your recommended eight glasses a day from bottled water, you could spend up to \$1,400 annually. The same amount of tap water would cost about 49 cents. Even if you installed a filter device on your tap, your annual expenditure would be far less than what you'd pay for bottled water.

For a detailed discussion on the NRDC study results, check out their Web site at www.nrdc.org/water/drinking/bw/exesum.asp.


Source Water Assessment

The RI Department of Health, in cooperation with other state and federal agencies, has assessed the threats to Woonsocket's water supply sources. The assessment considered the intensity of development, the presence of businesses and facilities that use, store, or generate potential contaminants, the ease with which contaminants can move through the soils in the Source Water Protection Area (SWPA), and the sampling history of the water.

Our monitoring program continues to ensure that the water delivered to your home is safe and wholesome. However, the assessment found that the water source is at moderate risk of contamination. This means that the water could one day become contaminated. Protection efforts are necessary to ensure continued water quality. The complete Source Water Assessment Report is available from Woonsocket Water Division at (401) 767-1411, or from HEALTH at (401) 222-6867.

Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/lead.



How Is My Water Treated and Purified?

The treatment process consists of a series of steps. First, raw water is drawn from our water source into the treatment plant. Chemicals are added to initiate the next process, called flocculation. The addition of these substances causes small particles to adhere to one another (called floc), making them heavy enough to settle to the bottom, from which sediment is removed. This process is called clarification, or sedimentation. The clear supernatant is then filtered through a deep-bed carbon filter that removes the smaller suspended particles. After filtration, the water undergoes disinfection, fluoride addition (to prevent tooth decay), corrosion inhibitor addition, and pH adjustment before it is pumped out into the distribution system.

QUESTIONS?

For more information about this report, or for any questions relating to your drinking water, please call Marc Viggiani, Water Superintendent, at (401) 767-1411 or visit our Web site at www.ci.woonsocket.ri.us or www.woonsocketri.org.

Failure in Flint

The national news coverage of water conditions in Flint, Michigan, has created a great deal of confusion and consternation over the past year. The water there has been described as being corrosive; images of corroded batteries and warning labels on bottles of acids come to mind. But is corrosive water bad?

Corrosive water can be defined as a condition of water quality that will dissolve metals (iron, lead, copper, etc.) from metallic plumbing at an excessive rate. There are a few contributing factors but, generally speaking, corrosive water has a pH of less than 7; the lower the pH, the more acidic, or corrosive, the water becomes. (By this definition, many natural waterways throughout the country can be described as corrosive.) While all plumbing will be somewhat affected over time by the water it carries, corrosive water will damage plumbing much more rapidly than water with low corrosivity.

By itself, corrosive water is not a health concern; your morning glass of orange juice is considerably more corrosive than the typical lake or river. What is of concern is that exposure in drinking water to elevated levels of the dissolved metals increases adverse health risks. And there lies the problem.

Public water systems are required to maintain their water at optimal conditions to prevent it from reaching corrosive levels. Rest assured that we routinely monitor our water to make sure that what happened in Flint never happens here. For more information on how corrosivity impacts water quality, download this informative pamphlet: <http://goo.gl/KpTmXv>.

Public Meetings

For public comment on an ongoing basis, customers can contact the office of Mayor Lisa Baldelli-Hunt or attend the Woonsocket City Council Meetings. The Council holds hearings on budget and other financial matters, approves contracts, and considers ordinances that create or amend local laws. Some of these matters affect the operation of the Woonsocket Water Division. The council meets on the first and third Mondays of every month at 7:00 p.m. in Harris Hall in City Hall, 169 Main Street, Woonsocket, RI. The meetings are televised live on Cox Cable Channel 17 and Verizon FIOS Channel 22. Public comment is welcome.

Where Does My Water Come From?


Woonsocket Water Division uses surface water from the Crookfall Brook and Harris Pond watersheds. The Crookfall Brook watershed extends over approximately 7.93 square miles. It is a protected, high-quality, and primary source of supply for the Woonsocket Treatment Plant. Harris Pond has a watershed area of approximately 33.3 square miles. This source is used as a supplemental source as needed. Woonsocket Water maintains an active watershed protection program and closely monitors the watershed lands to protect water quality.

UCMR3 Sampling

We participated in the 3rd stage of the EPA's Unregulated Contaminant Monitoring Rule (UCMR3) program by performing additional tests on our drinking water. UCMR3 benefits the environment and public health by providing the EPA with data on the occurrence of unregulated contaminants suspected to be in drinking water, in order to determine if EPA needs to introduce new regulatory standards to improve drinking water quality. Any UCMR3 detections are shown in the data tables in this report.

Availability of Monitoring Data for Unregulated Contaminants for Woonsocket Water Division

Our water system has sampled for a series of unregulated contaminants. As our customers, you have a right to know that these data are available including detected and nondetected test results. If you are interested in examining the results or more information on UCMR3, please contact Marc Viggiani at (401) 767-1411 or P.O. Box B, Woonsocket, RI 02895.



Sampling Results

During the past year, we have taken hundreds of water samples to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water.

The state requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

REGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Barium (ppm)	2015	2	2	0.036	0.015–0.046	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chlorine (ppm)	2015	[4]	[4]	0.37	ND–0.95	No	Water additive used to control microbes
Fluoride (ppm)	2015	4	4	0.61	0.07–0.97	No	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories
Haloacetic Acids [HAA] (ppb)	2015	60	NA	11.4	2.2–25.5	No	By-product of drinking water disinfection
Nitrate (ppm)	2015	10	10	0.273	0.100–0.490	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite (ppm)	2013	1	1	0.02	ND–0.02	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total Trihalomethanes] (ppb)	2015	80	NA	38.6	21.4–57.2	No	By-product of drinking water disinfection
Total Coliform Bacteria (% positive samples)	2015	5% of monthly samples are positive	0	0.92	NA	No	Naturally present in the environment
Total Organic Carbon (ppm)	2015	TT	NA	1.0	0–1.9	No	Naturally present in the environment
Turbidity¹ (NTU)	2015	TT	NA	0.329	0.014–0.329	No	Soil runoff
Turbidity (Lowest monthly percent of samples meeting limit)	2015	TT = 95% of samples < or = 0.3 NTU	NA	99.94	NA	No	Soil runoff

Tap water samples were collected for lead and copper analyses from sample sites throughout the community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	MCLG	AMOUNT DETECTED (90TH%TILE)	SITES ABOVE AL/ TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2014	1.3	1.3	0.05	0/32	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb)	2014	15	0	3	0/32	No	Corrosion of household plumbing systems; Erosion of natural deposits

SECONDARY SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	SMCL	MCLG	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Aluminum (ppb)	2015	200	NA	172	0–744	No	Erosion of natural deposits; Residual from some surface water treatment processes
Fluoride (ppm)	2014	2.0	NA	0.32	NA	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

UNREGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Sodium (ppm)	2015	99.7	70.7–120.0	Sodium naturally found in plants, soil and sodium compounds used for deicing roads

UNREGULATED CONTAMINANT MONITORING RULE PART 3 (UCMR3) ²

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Chlorate (ppb)	2013	17.61	ND–83.74	Disinfecting by-product; ions formed during the slow decomposition of sodium hypochlorite solution
Hexavalent Chromium (ppb)	2013	0.025	ND–0.06	Erosion of natural deposits; Produced by industrial processes
Strontium (ppb)	2014	59.75	58.848–60.642	Occurs naturally in the environment
Vanadium (ppb)	2014	0.701	0.586–0.816	Metal used as an alloying addition to iron and steel

¹ Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of the effectiveness of the filtration system.

² Contains additional RIDOH testing of unregulated contaminants.

Definitions

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

LRAA (Locational Running Annual Average): The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters. Amount Detected values for TTHMs and HAAs are reported as LRAAs.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

SMCL (Secondary Maximum Contaminant Level): SMCLs are established to regulate the aesthetics of drinking water like appearance, taste and odor.

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.