

**CITY OF WOONSOCKET
169 MAIN STREET
WOONSOCKET, RI 02895
401-767-9269
401-597-6604 Fax**


TO: All Bidders
FROM: Jessica L. Desrochers, Purchasing Dept.
DATE: December 13, 2016
SUBJECT: RFP-Police Department Generator Bid# 5764

ADDENDUM #2

Please note attached (7) pages of information pertaining to the above bid.

For further information, please contact Steven Gamache at sgamache@woonsocketri.org

**Thank you,
Jessica/Purchasing**



City of Woonsocket

Site plan and specifications

Police Department Generator

- 1) Emergency power supply during project period
- 2) Site Preparation
- 3) Site excavation
- 4) Building penetration
- 5) Conduit route through the interior of the building
- 6) All existing equipment and its contents

1) Emergency power supply during project period

Automatic emergency generation power shall remain or be supplied to existing generator panels until day of switch over to new installation and shall not be interrupted without approval and notification to the City of Woonsocket project coordinator.

2) Site Preparation;

A) City of Woonsocket Shall remove existing oil tank and shed for said tank.

B) City of Woonsocket Shall temporarily supply existing generator with fuel, **should** the existing generator be used for emergency power supply during the project period. If the CONTRACTOR were to use a portable generator for emergency supply, said generator **MUST** meet existing generator specs and existing generator would not be temporarily supplied with fuel.

C) City of Woonsocket Shall remove existing generator at completion of this project.

D) City of Woonsocket Shall remove concert pad for the existing oil tank and tree that is in the proposed Generator location.

3) Site excavation

A) Contractor shall be responsible for all pad preparation, trenching and back filling to rough grade to 2" minus. All frost precautions and applicable Building and electrical codes shall be upheld.

B) The City of Woonsocket complete finish grade and reseeding

4) Building penetration

A) Penetration into the building will be made and sealed by the contractor with a 2 year warranty made to the City of Woonsocket against leakage and/or seepage.

B) Contractor shall be responsible to avoid any damage to City of Woonsocket's equipment and fixtures and shall be liable for replacement with equal to or great then to any damaged items.

C) A) Penetrations are NOT to be located above any electrical panels in precaution of leakage during construction without written consent and approved method of precaution from the City of Woonsocket or the City's designated project manager.

5) Conduit route through the interior of the building

A) Contractor shall complete all penetrations and sealing of said penetrations with fire stop.

B) Conduit is to run above drop ceiling within the computer/radio room maintaining a " High as possible " route.

C) The remaining conduit route all maintain the "High as possible" through the remainder of the basement as to not affect any process or functionality of the Woonsocket Police Department.

E) Work completed in the evidence room will require a 24 hour notification and will only be conducted under the supervision of the Woonsocket Police Department personal or an appointed delegate from the Chief of police or the Command staff.

D) At each end of work day the Contractor shall maintain a clean work area as to minimize any disruption to the Woonsocket Police Department

6) All existing equipment and its contents

All existing equipment and its contents is to be considered the property of the City of Woonsocket and will not be removed from the property of the Police Department without written approval from the City of Woonsocket or its appointed delegate.

CONTRACTOR,

COMPANY NAME

CITY OF Woonsocket, a municipal
of the State of Rhode Island

Mayor

By: _____

print name

City Clerk

ITS: *(circle one)* Chairman/President/Vice President

AND

INITIATED AND APPROVED:

By: _____

print name

_____ Director/Chief

ITS: (circle one) Secretary/Chief Financial Officer/Asst.

Secretary - Treasurer

REVIEWED AND APPROVED:

City Administrator

APPROVED AS TO FORM:

City Attorney

New Generator location

French route

Maintain minimal clearances from building corners



