



## CHIMNEY & CLEANOUT DETAIL 1

N.T.S.

NOTE: SEWER LATERALS SHALL HAVE A MINIMUM 24" SEPARATION VERTICALLY AND 10' SEPARATION HORIZONTALLY FROM ALL WATER SUPPLY LINES

WOONSOCKET STANDARD  
SANITARY SEWER  
CHIMNEY & CLEANOUT DETAIL  
OPTION 1

CITY OF WOONSOCKET, RI  
DEPARTMENT OF PUBLIC WORKS  
ENGINEERING DIVISION  
OCTOBER, 2002