



DROP CLEANOUT ON PROPERTY DETAIL

N.T.S.

- NOTES: 1. SEWER LATERALS SHALL HAVE A MINIMUM 24" SEPARATION VERTICALLY AND 10' SEPARATION HORIZONTALLY FROM ALL WATER SUPPLY LINES.
 2. A TRANSITION MAY BE MADE BACK TO SDR35 PVC AT EITHER SIDE OF THE DROP CLEANOUT.
 3. A 6"x6"x4" WYE MAY BE USED TO TRANSITION FROM 6" TO 4" PIPE.

WOONSOCKET STANDARD
 SANITARY SEWER
 DROP CLEANOUT ON PROPERTY
 DETAIL

CITY OF WOONSOCKET, RI
 DEPARTMENT OF PUBLIC WORKS
 ENGINEERING DIVISION
 AUGUST, 2003